

PROJECT NO. 221334



**Peace River Town Hall – Accessibility
Upgrades
Peace River, Alberta**

ADDENDUM NO. TWO

May 18, 2022

This addendum forms part of the Tender Documents for Peace River Town Hall Accessibility Upgrade project, and modifies them as follows:

1.0 GENERAL INFORMATION (BIDDING & CONTRACT REQUIREMENTS)

1.1 SPECIFICATIONS

- .1 No items

1.2 QUESTIONS AND ANSWERS

- .1 Contractor wanted clarification if there was a preference for which panel wiring should run from, especially the heater.

A: Refer to the drawings for the panel specifications and locations and use best judgement where it is not specified which panel is to be used.

- .2 Contractor was unsure what was detailed for the lump sum for a data outlet as the location is not specified in the drawings.

A: Provide the pricing per outlet and the conduit and wire per meter.

2.0 ARCHITECTURAL

- .1 No items.

Attachment: Electrical Addendum E01

END OF ARCHITECTURAL ADDENDUM NO. TWO

May 17, 2022

ELECTRICAL ADDENDUM E01

REASON FOR ADDENDUM: Lift system electrical requirements co-ordination.

PREPARED BY: **ECCOM CONSULTING INC.**
Colin Schneider, P.Eng.

PROJECT: **Peace River Town Office Accessibility Upgrades**
Peace River, AB

ARCHITECT: **BR2 Architecture**


ECCOM PROJECT No: **2214**

NOTE: **THIS ADDENDUM FORMS PART OF THE TENDER DOCUMENTS AND MODIFIES THEM AS STATED HEREIN.**

ITEMS:

1. Drawing E04

REV: 4th Floor Stair 2 Area
Revise electrical connections for lift system to be as shown within the clouded region of the sketch below:





ECCOM CONSULTING INC.

13009 - 156 Street || Edmonton, Alberta, T5V 0A2

Tel::: 780.444.2200 || Fax::: 780.481.0005

Email::: info@eccom.ca

End of Addendum

ECCOM Consulting Inc.